

To be inserted between pages 44 & 45.

**Comm 66.0910 Plumbing.** Substitute the following wording for the requirements in IEBC section 910: Where the occupant load of a story is increased by more than 20 percent, plumbing fixtures for the story shall be provided in quantities specified in the IBC based on the increased occupant load.

**Comm 66.0911 Other requirements.** (1) ELEVATOR RECALL. This is a department rule in addition to the requirements in IEBC section 911: At least one existing elevator shall be provided with emergency recall operation and emergency in-car operation complying with ch. Comm 18 when an existing building or structure that is greater than 60 feet in height is changed to include a Group R-1 or R-2 occupancy.  
(2) CARBON MONOXIDE ALARMS. This is a department rule in addition to the requirements in IEBC section 911: A building or a portion of a building changed to be or include a residential building as defined under s. 101.149 (1) (b), Stats., shall be provided with carbon monoxide alarms or detectors in accordance with s. Comm 62.1200.